



GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE SUPERINTENDING ENGINEER, ZIRO ELECTRICAL CIRCLE
DEPARTMENT OF POWER :: ZIRO ::
Email: - apecvziro2008@gmail.com

No. SE/APEC-V/E-17/2023-24/

Dtd: Ziro, the

MINUTE OF PRE-BID MEETING

The Pre-Bid Meeting for the e-tenders under **Revamped Reforms-Based and Results-Linked, Distribution Sector Scheme(RDSS)** of the following packages was conducted on **24/08/2023** in the Conference Hall of the Superintending Engineer (E), Ziro Electrical Circle under the Chairmanship of Er. Duyu Tacho, SE (E), ZEC, Ziro. The meeting was attended by the concerned Divisional Officers, Officials, the Bidders as well as the representatives of intending/prospective bidders and the PMA Team (Wapcos) headed by Shri Ravinder Kumar. The names of the RDSS packages covered are: -

- 1) ZED/Lower Subansiri (01)/RDSS
- 2) YazED/Lower Subansiri (02)/RDSS
- 3) DaED/Upper Subansiri/RDSS
- 4) RaED/Kamle/RDSS
- 5) PaED/Kra Daadi/RDSS
- 6) KKED/Kurung Kumey/RDSS

The list of participants in the meeting is appended in Annexure – I.

On the outset of the meeting the Superintending Engineer (E), ZEC, Ziro welcomed all the participants who attended the Pre-bid Meeting. The following queries from the bidders present and also received through emails were deliberated upon and clarified as shown below: -

Sl. No.	Bidders Queries	Clarification
1	AAA Covered Conductor 52.88 sqmm in place of 120sqmm as followed by other Northeastern State.	Modification of certain specification are being taken up with the competent authority, whose outcome will be intimated in due course of time.
2	Whether GTP required to be submitted in Bid Documents.	Not required at time of bid.
3	Who will be Signatory of Integrity pact on behalf of Power Department and whether signature form the concern officer should be taken before Bid Submission.	Executive Engineer (E) of the package concerned, but his signature is not required at the time of the bid.
4	Whether DRG,GCCSCC,SBD, Schedule Erection, schedule Grand summary, Schedule supply, SoW, TS documents is to be uploaded online with digitally sign.	SBD is to be uploaded online with digitally signed.
5	Whether quoted rate will be inclusive of GST or not.	Separate columns are provided for GST.
6	Whether the name of the vendors supply plant and machineries to be given with Bid Documents.	Not at the time of bid
7	Whether all the tender documents should be digitally sign while submitting in online.	Yes
8	In some Pre-Bid meeting it is observed that the employer has said that the Bank Guarantee is not acceptable. In this RFB of this project it is clearly mentioned that Bank guarantee can be given as Bid Security and for that purpose Form-3B is provide in the RFB kindly clear the matter.	Bank Guarantee for EMD is not acceptable.

Sl. No.	Bidders Queries	Clarification
9	Does the integrity pact (Form-21) need to be notarized and uploaded	Yes.
10	There are two types of BOQ that needs to be uploaded. One is Excel and other on if PDF. If so should the Excel one be converted into PDF and uploaded?	Both Excel and PDF being the same BOQ, the PDF is to serve as confirmation copy.
11	Does all affidavit need to be notarized?	Yes.
12	Electrical line layout plan including length where development/revamping is to be done. May please be provided to us.	Successful bidder will be provided with detail layout plans.
13	Since funding is from Central Govt and from State Government, please ensure to make payment timely as per terms of contract though interest is payable by employer for delayed payment.	As per payment terms in the SBD.
14	Transit insurance shall be 120% of the Ex-factory price required separately, please confirm as in appendix 3.	As per condition set in SBD.
15	Coverage of Earthquack under insurance policy generally depends upon the scale of earthquack. Please intimate the Richter Scale/ Magnitude of WQ upto which policy to be taken. Insurance companies always ask for the limits.	As per condition set in SBD.
16	Employment's supply (Appendix 6 of part 3)- since electricity and water is to be provided by the Employer, it would be useful if how same is going to be provided/arranged looking to the nature of work. The changes may also be indicted.	In the locations where electricity and water are available, the employer will supply the same at the prevalent rates to be borne by contractor . In the location where electricity and water are not available the contractor has to arranged on their own.
17	List of approved contractor may please be given.	Not required.
18	Since the time gap between the pre-bid meeting and opening date of tender is very low, the date of opening be extended for 15 days.	Being extended.
19	We didn't find the approved vendor list in the tender documents on the website.	Not required at the time of bid.
20	ROW payment for the land and crop compensation and assessment of crops payment who scope please clarify.	As per Part-3 (GCC) Clause No. 10.2.
21	Tender value mentioned in tender notice is included GST or excluding GST please clarify.	Including GST.
22	The contract agreement composite or separate for supply please clarify.	Separate for supply and erection, but with cross fall breach.
23	In Clause No. 18.2,C. for EMD BG validity period 180 or 270 please confirm.	Does not arise, since BG is not acceptable for EMD.
24	In ITB 44.1 please clarify for performance security about 3% of the contract value and any additional performance required.	Performance security is 3% of the contract value. Additional performance security (if applicable only) as per SBD.
25	GTPs and Drawings are required along with Bid Submission.	Not at the time of bid.
26	Labor CESS applicable or not if applicable include in bid submission.	Labour cess applicable for erection part.
27	Earthing set quantity for Transformer each one set given in BOQ please confirm how many earths each transformer and clarify set means how many earths.	One each for body, neutral and LA.
28	BOQ is uncertain about quantity as per site condition. Dead end clamp and all accessories can they vary as per survey. Wedge connectors where will they be used? Sl. No. 9,10,11,12,13,14 to 24.	BOQ is correct, however, with the successful bidder exact quantity shall be ascertained as per survey.
29	Instead of 1% EMD 2% is mentioned, why it cannot be 1% EMD for APST bidder.	As per Standard Bidding Documents adapted for this Central scheme, the EMD is 2%.

Sl. No.	Bidders Queries	Clarification
30	L1 bidder to be awarded and from which range will be counted as abnormal lowest bid.	The result of evaluation will determine whom to award.
31	Physical submission of the tender or only those part specified by the ITB 11.3.	As specified in ITB 11.3 only.
32	Whether copies of GTPs should be submitted alongwith the tender or after the award of the work.	Not required at the time of bid.
33	Submission of signed copy of entire SBD (tender documents) or acceptance of SBD on letterhead is sufficient.	SBD to be signed.
34	The tender does not contain the LT ABC Technical Specification, TS is required to submit the GTP.	Not required at the time of bid.
35	There are 2 different Bid Security Forms, one is SBD(part-I) and another is GCC(part-3) which one to be opted for Bank Guarantee.	BG not acceptable for bid security/EMD.
36	Engineering drawing is to be submitted. Are there specific drawings to be submitted.	GTP and drawing are to be submitted by successful bidder for approval after award.
37	Permission from Railways to cross the line will be taken by the employer for carrying out by the contractor.	Not applicable
38	As per clause No. 37 of ITB it is mentioned "The percentage is 70%.	Not applicable.
39	We understand the concern, and would like to convey that we are acquainted with the terrain and site locations. Further, perceiving the present weather conditions we would request you to add provisions for submission of undertaking/letter of compliance stating that the bidder is familiar with the site locations and site visits not mandatory. This will also reduce the additional cost/expenses to the competitive bidders.	Site visit mandatory

The above clarification to the queries may be considered as addendum to the SBD of all the aforementioned packages.

The Meeting ended with vote of thanks by the Executive Engineer (Plg), Ziro Electrical Circle, Department of Power, Ziro.

Superintending Engineer (E)
Ziro Electrical Circle,
Deptt. of Power, Ziro.

No. SE/APEC-V/E-17/2023-24/ 568-69
Copy to: -

Dtd: Ziro, the 24/8/23

1. The Under Secretary to the Hon'ble DCM/Minister (Power), Government of Arunachal Pradesh, for kind information of the Hon'ble DCM.
2. PS to the Commissioner (Power) Government of Arunachal Pradesh for favor of kind information please.
3. The Chief Engineer (P), EEZ / CEZ / WEZ for kind information please.
4. The State Nodal Officers (SNO) RDSS, EEZ, Department of Power, Itanagar for kind information please.
5. The Superintending Engineer (Elect.), APEC-I / II / III / IV for kind information please.
6. The Executive Engineer (E), ZED / DaED / KKED / PaED/ RaED / YazED for information and necessary action.
- ✓ 7. The NIC for kind information with request to upload in the website www.arunachaltenders.gov.in / www.arunachal.gov.in
8. Office Copy.



Superintending Engineer (E)
Ziro Electrical Circle,
Deptt. of Power, Ziro.

ANNEXURE - I

Attendance Sheet for the Pre-Bid Meeting on 24/08/2023 in the Conference Hall of SE (E), Ziro Electrical Circle, Dept. of Power, Ziro, pertaining to the following RDSS packages: -

- 1) ZED/Lower Subansiri (01)/RDSS
- 2) YazED/Lower Subansiri (02)/RDSS
- 3) DaED/Upper Subansiri/RDSS
- 4) RaED/Raga/RDSS
- 5) PaED/Kra Daadi/RDSS
- 6) KKED/Kurung Kumey/RDSS

Sl. No.	Name of Firm	Name of Representative	Email and Contact No.	Signature
1	M/s A. R. Ent.	Pop. Knoch Raja	8837479691 woodraya2013@gmail.com	
2	M/s Electrotech Projects Pvt Ltd.	— do —	— do —	
3	M/s Onycon Infra LLP	Prasanjit Dew.	7002087284	Prasanjit Dew.
4	M/s Onycon Infra M/s Onycon Infra	Yogendra Kumar Puraink	966444125 gkp.con.onycon@gmail.com	YCB
5	KRISHNA URJA CONSTRUCTIONS LLP	SAME BARMAN	7005673148 PANUJI.AP@GMAIL.COM	
6	M/s Industrial system LLP	Bikesh Prasad Chauvaha	9082811163 COO@dhampurmanet	Bpch
7	M/s Reniya Enterprise	Tage Sambio	9436040000 tage.sambio@gmail.com	
8	M/s Reniya Enterprise	Tage Sambio Harlyang	8730996911	
9	M/s D & G Control	Nangria Jonop	8974484384	
10	M/s D & G Control	Kako Bin	7085633102	
11	M/s A. R. Enterprise	Tania Tajny	9612433104	
12	M/s Electronic project	Tania Tajny	9612433104	
13	M/s Dee Control & Electronic (P)	Ata Prabung Tanya	9382034594 9792982818	
14	M/s Tanya Projects	Uwaha Taja	897430078	
15	M/s Pa Associates	Techi Taja	7002518623	
16	TBI Projects	Techi Taja	7002518623	T. Taja
17	M/s Renia Enterprise	N. Tony	7005015095	N. Tony

18	M/S.T.S Power Co.	Maryam Dobin	9436072297 8414816710	
19	M/S SRV PILLAI	TRKO Tolan	982234157	
20	Anil Electrical	Dr. Sanjay Hini	7088118800	
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				

SL No	NAME OF OFFICIAL/ OFFICER	DIVISION/CIRCLE	EMAIL/ CONTACT	SIGNATURE
1	Er. Duryu Tacho	SE(B) APEC-V.	841A077247	
2	Er. Ayali Taki	EB (R) Phg.	8794312170	
3	Narinder Umm	T.L. PMA RDJ	9991116111	
4	Musawvir Ansari	Export, PMA, RDSS	9936988174	
5	Er. Purnyo Hinda.	EE(E), PaED	9612917301	
6	Er. Dogin Tada	E.E.(E), ZED.	7085242512	 24/8/23
7	Er. Tadar Rade	EE(E), KKED	9862516853	 24/8/23
8	Shri Kabak Vicky	JE(E) KRED	8415993391	
9	Mr. Hueba Nijm	KH(lect.) KaED	8152818978	
10	Pijay Mudein	EE(E), DoED.	8974113850	
11	Bhupak Koinya	AE(E) Talika	9436220732	
12	A.K. Rao	80 esthadrn	9436097920	
13	Ojing Jerang	EE(E), Yazali	8974640622	
14	Hage Daryang	J.E(E) ZED	8415986470	
15	Neelan Kaban	AE(E), Yazali	9774698822	
16	Hage Gumbo	JE(E), Zino	8729803568	
17	Nabam Epo Hina	A.E(E) C1000	6009963140	 24/8/23
18				
19				
20				